



ANGELES ELECTRIC CORPORATION

EMERGENCY POWER OUTAGE ADVISORY

DATE : August 23, 2024
TIME : 06:48PM to 8:27PM

DETAILS :

Short circuit fault at the 69kV Petersville - Calibu Subtransmission Line at McArthur Hwy., Telabastagan, in front of "The Orchard".

Affected Areas:

- Brgy. Sto. Rosario
- Brgy. Anunas
- Brgy. Cuayan
- Portion of Brgy. Malabantias
- Brgy. San Nicolas
- Brgy. Lourdes Northwest
- Brgy. Lourdes Sur
- Brgy. Sta. Trinidad
- Brgy. Sta. Teresita
- Brgy. Agapito Del Rosario
- Brgy. Pampang
- Brgy. Cutcut
- Brgy. Amsic (Pulu Amsic)
- Brgy. San Jose
- Brgy. Sto. Domingo
- Brgy. Pulungbulu
- Brgy. Telabastagan
- Xevera Calibutbut, Bacolor
- Town & Country Homes
- AIPI Cmpd.
- Villagio Real

Findings :

Big Acacia tree branches laid on the 69kV Subtransmission Line due to sudden heavy rains with strong winds.

Action Taken :

- Cleared / removed tree branches from the 69kV Subtransmission Line

For your information and guidance.