



ANGELES ELECTRIC CORPORATION

EMERGENCYPOWER OUTAGE ADVISORY

DATE : **September 18, 2024**

TIME : **12:36PM to 1:05PM**

DETAILS :

NGCP line tripping at the 69kV Mexico-Angeles Line1 and Line 2 at NGCP Mexico Substation Compound

Affected Areas:

- **AEC Franchise Area**

Findings :

Possible short circuit fault at the 69kV Mexico-Angeles Line1 and Line 2 along NLEX-South Bound

Action Taken :

- Energized 69kV Mexico-Angeles Line1 and Line 2 at NGCP Mexico Substation Compound and power restored to normal at around 1:05PM

For your information and guidance.



ANGELES ELECTRIC CORPORATION

EMERGENCYPOWER OUTAGE ADVISORY

DATE : **September 18, 2024**

TIME : **12:36PM to 1:05PM**

DETAILS :

NGCP line tripping at the 69kV Mexico-Angeles Line1 and Line 2 at NGCP Mexico Substation Compound

Affected Areas:

- **AEC Franchise Area**

Findings :

Possible short circuit fault at the 69kV Mexico-Angeles Line1 and Line 2 along NLEX-South Bound

Action Taken :

- Energized 69kV Mexico-Angeles Line1 and Line 2 at NGCP Mexico Substation Compound and power restored to normal at around 1:05PM

For your information and guidance.