



ANGELES ELECTRIC CORPORATION

EMERGENCYPOWER OUTAGE ADVISORY

DATE : **September 10, 2024**

TIME : **04:20PM to 4:55PM**

DETAILS :

Short circuit fault at the 69kV Mexico-Angeles Line1 at NGCP Mexico Substation Compound

Affected Areas:

- **AEC Franchise area**

Findings :

Minor damage on 69kV line wire

Action Taken :

- All feeder breakers were energized at 04:55 PM of September 10, 2024.

For your information and guidance.