



ANGELES ELECTRIC CORPORATION

EMERGENCY POWER OUTAGE ADVISORY

DATE : **November 07, 2024**
TIME : **10:02AM to 10:27AM**

DETAILS :

NGCP line tripping at the 69kV Mexico-Angeles Line1 and Line 2 at the NGCP Mexico Substation Compound

Affected Areas:

- **AEC Franchise Area**

Findings :

Possible short circuit fault at the 69kV Mexico-Angeles Line1 and Line 2 along NLEX-South Bound

Action Taken :

- Energized 69kV Mexico-Angeles Line1 at NGCP Mexico Substation Compound and power restored to normal at around 10:27AM

For your information and guidance.